

Operating High Variable, Renewable Generation Power Systems

Lessons Learned from Ireland and Northern Ireland


16th September 2015

Overview



EirGrid's Role


EirGrid is the Transmission System Operator and Market Operator



* Note: In Ireland ESB owns the transmission and distribution system

Power System of Ireland and Northern Ireland

- 9000 MW of conventional plant
 - Relatively large units (several > 400 MW)
- 2800 MW of Windfarms
- Peak Demand of ~6800 MW
- Valley Demand ~2300 MW
- Total annual demand ~36 TWh
- HVDC Interconnection: 1000 MW
 - NI & GB: Moyle (500 MW)
 - IE & GB: EWIC (500 MW)




2020 RES-E Targets

%



2020 Renewable Electricity Targets Across the EU

Wind as % of Demand

Source: The National Renewable Energy Action Plans (NREAP) January, 2012
 Note: The Danish wind target was increased subsequently in quarter 2 of 2012




Ireland Fuel Statistics 2010 - 2013



Figures courtesy of Sustainable Energy Authority of Ireland

Changing Portfolio: Changing System Needs




Facilitation of Renewables




Key Finding 1: Frequency Control and Impact of ROCOF Relays

The management of frequency following the loss of the largest unit will become progressively more difficult at high penetration of wind. In addition the use of ROCOF relays, currently employed on all distribution connected windfarms, further threatens frequency stability.




Key Finding 1: Frequency Control Mitigation Measures: Impact on Disabling RoCoF




Key Finding 2: Single Largest Contingency may change

With large amounts of wind power, a transmission fault of 100ms has the potential to result in a MW reduction greater than that of the largest single in-feed, potentially resulting in serious frequency events.

Faults with wind reductions > 400MW




Winter Maximum, 75% Wind - Post fault wind MW reductions



Key Finding 3: Dynamic Stability Issues

Moderate amounts of wind power increase dynamic stability, but at high levels of wind power penetration, dynamic stability deteriorates significantly




Key Finding 4: Voltage and Reactive Power Control


The management of both steady state and dynamic reactive control becomes difficult with the addition of significant amounts of wind.

- Requirement for significant reactive support in base case
- Modelling showed over compensated system can lead to voltage collapse at high per unit voltages
- Dynamic Response from all generators necessary to manage stability issues


Example of Incident




Frequency Response: Inertia




Frequency Response: Inertia




Reactive Power – Synchronised



Reactive Power – Synchronised




Facilitation of Renewables



- RoCoF capability and protection
- Conventional Generator Reserve performance
- Windfarms controllability and reactive power capability
- New operating procedures including embedded windfarms

DS3 Programme

Background – Operations and DS3



Detailed Technical Analysis

- 2008 - All Island Grid Study
- 2010 - Facilitation of Renewables
- 2011 - Ensuring a Secure Sustainable System

Delivering a Secure Sustainable System


- 2011 – Programme established
- Meeting the RES Policy Objectives efficiently while maintaining system security
- Holistically considering technical, commercial and regulatory needs of the system
- Engaging with all industry stakeholders



DS3 – Shaping the System of the Future



Real-Time Operational Limits and Impact on RES-E




Challenges and Responses

Facilitating up to 75% Renewables in real-time requires change

Challenges


- System Stability
- Resource Variability
- Uncertainty
- New connections
- Changed power flows




Infrastructure: Network and Interconnectors




Operational: DS3 and Smart Grids



Constraints vs. Curtailment




Effect of SNSP on Curtailment



Illustrative SNSP curves


IRE & NI: Dispatch Down by Hour of Day




Today: Enabling 50% in Real Time

1. Active and reactive control of windfarms
2. Best in class wind forecasting
3. On-line real-time dynamic assessment
4. Enforcement of standards on all generators


SNSP – Early 2015



Wind Generation – Early 2015




Example – Exporting When Wind/Load > 50%



Tomorrow: Enabling 75%.....

1. Additional System Services
2. RoCoF to 1 Hz/s over 500 ms
3. Revised Operational Policies
4. New Control Centre Tools



Driver for System Services

RoCoF

**Lack of
Synchronising
Torque**

**Voltage Dip
Induced
Frequency
Dips**

**Low
System
Inertia**


**Frequency
Nadirs**

**System
Ramping
Capability**


**Reactive
Power
Shortfall**

Incentivising the Portfolio: Market Signals

- Incentivising performance of plant
- Financial Mix will move to higher capital lower variable cost technologies
- Obtaining the plant mix that matches the system requirements and achieves the policy objectives




DS3 System Services Frequency Products



- Synchronous Inertial Response
- Fast Frequency Response
- Fast Post-Fault Active Power Recovery


- Ramping Margin

DS3 System Services Voltage Products



RoCoF – Move to New Standard

- Current standard: 0.5 Hz/s
- Proposed standard:
 - 1.0 Hz/s measured over 500 ms
- Differing industry perspectives
 - Wind farms – no issues
 - DSOs require ‘LoM’ protection changes
 - Conventional generators have concerns



RoCoF Implementation Project


Generator Studies
Project

TSO-DSO
Implementation
Project


Alternative /
Complementary
Solutions Project

“Plan A”

“Plan B”



Realising Potential of DSO Generation




TSO-DSO Engagement




Voltage Control

- DSO implemented TSO-DSO agreed changes at Cauteen wind farm cluster
- Interim measure to improve voltage stability in the area
- Wider reactive compensation studies underway
 - Value of DSO windfarms: significant off setting of transmission reactive compensation requirements




2025	Power Factor of TYPE B Wind Farms	MVar Required
WP	0.95 Leading	145
WP	0.98 Leading	105
WP	Unity Power Factor	55
WP	Voltage control \pm 0.95	15 40

Operational Policies



DS3: Operational Control Process



Control Centre Tools


Existing Control
Centre Tools

2011

New Tools

Regulation, Ramping, Voltage
Trajectory....

2015 - 2017



Tools Delivered

WSAT, Short Circuit, Wind
Dispatch, Synchrophasor....

2012 - 2015



Blue Sky
Thinking

2017 - 2020


Ramping Example




Ramping




Ramping Concept




Ramping Concept




Ramping Concept




Ramping Concept




Ramping Concept




Ramping Concept




Ramping Concept



Ramping Concept




Ramping Margin (RM1, RM3 & RM8)



Summary

Complementary Progress Essential




DS3 Programme Summary

- Regularly operating at 50% SNSP and 65% wind/load
- RoCoF workstream progressing
- System Services underway but significant design and implementation issues need to be worked through
- Need to maximise contribution from embedded generation – DSO/DNO input key
- Operational policy and tools need to be developed in parallel in a considered manner

Energy sector is going through a period of remarkable transition

EirGrid's experience can be leveraged to benefit other power systems



Sowing the Seeds of solution

